



水務署  
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (2) in WSD 3321/2021 T/J(661/2021)  
Our ref.  
來函檔號 :  
Your ref.

電話 :  
Tel.  
傳真 : 2824 0578  
Fax.

31 May 2021

Towntube Hong Kong Ltd.  
G/F., No.5, 2nd Street,  
Kak Tin Village, Shatin,  
N.T., Hong Kong

(Attn.: Ms Kellie CHENG)

Dear Madam,

**Approval of "TOWNTUBE" Galvanized Steel Pipe  
(General Acceptance No. C20210564FS)**

Your letter dated 14 April 2021 refers.

Having considered the test report ref. J25437r1 issued on 20 January 2021 by Nutek Systems (HK) Limited, this Authority accepts that the pipe described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:** Guangdong Zhenhong Co Ltd  
**Country of Origin:** the Mainland of China  
**Brand:** Towntube  
**Details of Pipe:** Galvanized steel pipe (class medium)  
**Size:** 200mm  
**Body Markings:** TOWNTUBE BE EN 10217 SERIES MEDIUM  
W DN 200mm x 1M  
**Expiry Date:** 5 July 2025

**Proviso:** The pipe can only be used in fresh water fire service systems.

This Authority hereby permits the use of the above pipe in fresh water fire service systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipe to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipe installed fails to meet that of the approved sample or if the pipe is found to be unsuitable for use in fresh water fire service systems.

For the use of the pipe in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipe by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82 ] - without catalogue  
ME/MC ] - with soft copy only